

Malabar Wastewater Treatment Plant

July Pollution Monitoring Summary

Air Quality



EPL 372

Licensee: Sydney Water
PO Box 399
PARRAMATTA NSW 2124

Summary period: 01-07-2021 to 31-07-2021
Date obtained: 13-08-2021
Date published: 18-08-2021

Table 1: Routine monitoring data

EPA Point 1	Point description: Air sampling outlet of the foul air scrubbers						
pollutant	unit of measure	sampling frequency	number of samples	minimum result	maximum result	maximum limit	within limits*
chlorine gas	mg/m ³	30 minutes	1488	<0.30	<0.30	200	yes
hydrogen sulphide gas	mg/m ³	30 minutes	1488	<0.07	0.37	5	yes

*Maximum limits for air quality are based on the *Protection of the Environment Operations (Clean Air) Regulation 2010 - Schedule 4 Standards of concentration for scheduled premises: general activities and plant.*