



Bondi Wastewater Treatment Plant
2017-18 Pollution Monitoring Summary
Air Quality

EPL 1688

Summary period: 01-06-2017 to 30-06-2018
Date obtained: 20-06-2018
Date published**: 14-05-2018

Licensee: Sydney Water
PO Box 399
PARRAMATTA NSW 2124

Table 1: Routine monitoring data

EPA Point 11		Point description: Air sampling outlet of cogeneration facility				
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
nitrogen oxides	mg/m ³	yearly	3	439	450	459

** Report has been updated to include nitrogen oxides that were inadvertently omitted from the original report.