

Malabar Wastewater Treatment System

2017-18 Air quality pollution monitoring summary

EPL 372

Summary period: 1-07-2017 to 30-06-2018

Date published: 14-09-2018

Licensee: Sydney Water

PO Box 399

PARRAMATTA NSW 2124

EPA Point 1	Point description: Air sampling outlet of the foul air scrubbers at Malabar WWTP							
pollutant	unit of measure	sampling frequency	number of samples	minimum	average	maximum	maximum limit	% within limits
chlorine gas	mg/m ³	30 minutes	17520	<0.30	<0.30	10.83	200	100%
hydrogen sulphide gas	mg/m ³	30 minutes	17520	<0.07	<0.07	1.03	5	100%

*Maximum limits for air quality are based on the *Protection of the Environment Operations (Clean Air) Regulation 2010 - Schedule 4 Standards of concentration for scheduled premises: general activities and plant.*

EPL 372

Date obtained: 04-05-18

Date published** : 14-05-2019

Licensee: Sydney Water

PO Box 399

PARRAMATTA NSW 2124

EPA Point 84	Point description: Air sampling outlet of cogeneration facility at Malabar WWTP					
pollutant	unit of measure	sampling frequency	number of samples	minimum	average	maximum
nitrogen oxides	mg/m ³	yearly	4	423	431	442

** Report has been updated to include nitrogen oxides that was inadvertently omitted from the original report.

Malabar Wastewater Treatment System

2017-18 Air quality pollution monitoring summary

EPL 372

Date obtained: 17-05-2018

Date published** : 14-05-2019

Licensee: Sydney Water

PO Box 399

PARRAMATTA NSW 2124

EPA Point 86		Point description: Air sampling outlet of cogeneration facility at Liverpool WWTP				
pollutant	unit of measure	sampling frequency	number of samples	minimum	average	maximum
nitrogen oxides	mg/m ³	yearly	4	411	438	460

** Report has been updated to include nitrogen oxides that was inadvertently omitted from the original report.

EPL 372

Date obtained: 17-05-2018

Date published** : 14-05-2019

Licensee: Sydney Water

PO Box 399

PARRAMATTA NSW 2124

EPA Point 85		Point description: Air sampling outlet of cogeneration facility at Glenfield WWTP				
pollutant	unit of measure	sampling frequency	number of samples	minimum	average	maximum
nitrogen oxides	mg/m ³	yearly	4	439	447	454

** Report has been updated to include nitrogen oxides that was inadvertently omitted from the original report.