

North Head Wastewater Treatment Plant

2018-19 Air quality pollution monitoring summaries



EPL 378

Summary period: 1-07-2018 to 30-06-2019

Date published: 09-09-2019

Licensee: Sydney Water

PO Box 399

PARRAMATTA NSW 2124

EPA Point 33		Point description: Ventilation outlet at Scotts Creek						
pollutant	unit of measure	sampling frequency	number of samples	minimum	mean	maximum	maximum limit	% within limits*
hydrogen sulphide gas	mg/m ³	30 minutes	17518	<0.004	<0.004	0.058	5	100%

EPA Point 34		Point description: Ventilation outlet at Lane Cove River West						
pollutant	unit of measure	sampling frequency	number of samples	minimum	mean	maximum	maximum limit	% within limits*
hydrogen sulphide gas	mg/m ³	30 minutes	17518	<0.004	<0.004	0.128	5	100%

EPA Point 35		Point description: Ventilation outlet at North Head STP for Northside Storage Tunnel						
pollutant	unit of measure	sampling frequency	number of samples	minimum	average	maximum	maximum limit	% within limits*
hydrogen sulphide gas	mg/m ³	30 minutes	17518	<0.01	0.04	7.07	5	99.99% ¹

*Maximum limits for air quality are based on the *Protection of the Environment Operations (Clean Air) Regulation 2010 - Schedule 4 Standards of concentration for scheduled*

¹ Details of operation issues were provided in monthly report for 2018-19.

North Head Wastewater Treatment Plant

2018-19 Air quality pollution monitoring summaries

EPL 378

Summary period: 1-07-2018 to 30-06-2019

Date published: 03-10-2019

Licensee: Sydney Water

PO Box 399

PARRAMATTA NSW 2124

EPA Point 63		Point description: Central scrubber outlet at North Head STP						
pollutant	unit of measure	sampling frequency	number of samples	minimum	average	maximum	maximum limit	% within limits*
chlorine gas	mg/m ³	30 minutes	17518	<0.15	0.89	3.48	200	100%
hydrogen sulphide gas	mg/m ³	30 minutes	17518	<0.075	<0.075	1.767	5	100%

EPA Point 66		Point description: Bio Trickling Filter / Standby Scrubber at North Head STP						
pollutant	unit of measure	sampling frequency	number of samples	minimum	average	maximum	maximum limit	% within limits*
chlorine gas	mg/m ³	30 minutes	17518	<0.59	<0.59	1.00	200	100%
hydrogen sulphide gas	mg/m ³	30 minutes	17518	<0.071	<0.071	2.442	5	100%

*Maximum limits for air quality are based on the *Protection of the Environment Operations (Clean Air) Regulation 2010 - Schedule 4 Standards of concentration for scheduled premises: general activities and plant*.

North Head Wastewater Treatment Plant

2018-19 Air quality pollution monitoring summaries

Summary period: 1-07-2018 to 30-06-2019

Date published: 09-09-2019

Licensee: Sydney Water

PO Box 399

PARRAMATTA NSW 2124

EPA Point 64		Point description: Air sampling outlet of cogeneration facility unit 1 at North Head STP				
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
nitrogen oxides	mg/m ³	yearly	3	392	395	400

EPA Point 65		Point description: Air sampling outlet of cogeneration facility unit 2 at North Head STP				
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
nitrogen oxides	mg/m ³	yearly	3	352	358	368