

Warriewood Wastewater Treatment Plant
2019-20 Air quality pollution monitoring summary



EPL 1784

Summary period: 01-07-2019 to 30-06-2020
Date published : 10-08-2020

Licensee: Sydney Water
PO Box 399
PARRAMATTA NSW 2124

Table 1: Routine monitoring data

EPA Point 25		Point description: Air sampling outlet of cogeneration facility				
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
nitrogen oxides	mg/m ³	yearly	3	260	271	288

Yearly measurement taken on 29-11-2020.