

Wollongong Wastewater Treatment Plant
2020-21 Air quality pollution monitoring summary



EPL 218

Summary period: 01-07-2019 to 30-06-2020
Date published : 16-08-2020

Licensee: Sydney Water
PO Box 399
PARRAMATTA NSW 2124

Table 1: Routine monitoring data

EPA Point 29		Point description: Air sampling outlet of cogeneration facility				
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
nitrogen oxides	mg/m ³	yearly	4	324	332	340

Yearly measurement taken on 22-11-2020.