

Bombo Wastewater Treatment Plant

June Pollution Monitoring Summary



EPL 2269

Summary period: 01-06-2020 to 30-06-2020

Date obtained: 08-07-2020

Date published: 14-07-2020

Licensee: Sydney Water Corporation

PO Box 399

PARRAMATTA NSW 2124

Table 1: 3 Day Geometric Mean data

EPA Point 4 Site code BO0004		Point description: At the end of the chlorine contact tanks			
pollutant	unit of measure	sampling frequency	3DGM limit	3DGM Actual	within limits
total suspended solids	mg/L	monthly	50	<2	yes

3 Day Geometric Mean (3DGM) is a way to average a set of values and is commonly used with water quality assessments which show a great deal of variability. 3DGM is calculated by multiplying the results of the analysis of three samples collected on three consecutive days and then taking the cubed root of that amount.

Table 2: Routine monitoring data

EPA Point 4 Site code BO0004		Point description: At the end of the chlorine contact tanks				
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
aluminium	ug/L	monthly	1	-	-	19
carbonaceous biochemical oxygen demand	mg/L	every 6 days	5	<2	<2	<2
copper	ug/L	monthly	1	-	-	2.1
diazinon	ug/L	monthly	1	-	-	<0.1
nitrogen (ammonia)	mg/L	monthly	1	-	-	0.6
nonylphenol ethoxylate	ug/L	monthly	1	-	-	<5
total suspended solids	mg/L	every 6 days	5	<2	<2	<2

EPA Point 13 Site code BO0013		Point description: In the channel after the dechlorination unit				
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
faecal coliforms	CFU/100mL	every 6 days	5	<1	<1	3
hydrogen sulphide (unionised)	ug/L	monthly	1	-	-	<30
sea urchin fertilisation (EC50)	% Effluent/Vol	monthly	1	-	-	100

Average and percentile limits are only applied annually for routine monitoring data in Table 2

Bombo Wastewater Treatment Plant

May Pollution Monitoring Summary



EPL 2269

Summary period: 01-05-2020 to 31-05-2020

Date obtained: 05-06-2020

Date published: 17-06-2020

Licensee: Sydney Water Corporation

PO Box 399

PARRAMATTA NSW 2124

Table 1: 3 Day Geometric Mean data

EPA Point 4 Site code BO0004		Point description: At the end of the chlorine contact tanks			
pollutant	unit of measure	sampling frequency	3DGM limit	3DGM Actual	within limits
total suspended solids	mg/L	monthly	50	2	yes

3 Day Geometric Mean (3DGM) is a way to average a set of values and is commonly used with water quality assessments which show a great deal of variability. 3DGM is calculated by multiplying the results of the analysis of three samples collected on three consecutive days and then taking the cubed root of that amount.

Table 2: Routine monitoring data

EPA Point 4 Site code BO0004		Point description: At the end of the chlorine contact tanks				
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
aluminium	ug/L	monthly	1	-	-	20
carbonaceous biochemical oxygen demand	mg/L	every 6 days	5	<2	<2	<2
copper	ug/L	monthly	1	-	-	3
diazinon	ug/L	monthly	1	-	-	<0.1
nitrogen (ammonia)	mg/L	monthly	1	-	-	1.7
nonylphenol ethoxylate	ug/L	monthly	1	-	-	<5
total suspended solids	mg/L	every 6 days	5	<2	<2	4

EPA Point 13 Site code BO0013		Point description: In the channel after the dechlorination unit				
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
faecal coliforms	CFU/100mL	every 6 days	5	<1	1	3
hydrogen sulphide (unionised)	ug/L	monthly	1	-	-	<30
sea urchin fertilisation (EC50)	% Effluent/Vol	monthly	1	-	-	100

Average and percentile limits are only applied annually for routine monitoring data in Table 2

Bombo Wastewater Treatment Plant

April Pollution Monitoring Summary



EPL 2269

Summary period: 01-04-2020 to 30-04-2020

Date obtained: 05-05-2020

Date published: 15-05-2020

Licensee: Sydney Water Corporation

PO Box 399

PARRAMATTA NSW 2124

Table 1: 3 Day Geometric Mean data

EPA Point 4 Site code BO0004		Point description: At the end of the chlorine contact tanks			
pollutant	unit of measure	sampling frequency	3DGM limit	3DGM Actual	within limits
total suspended solids	mg/L	monthly	50	2	yes

3 Day Geometric Mean (3DGM) is a way to average a set of values and is commonly used with water quality assessments which show a great deal of variability. 3DGM is calculated by multiplying the results of the analysis of three samples collected on three consecutive days and then taking the cubed root of that amount.

Table 2: Routine monitoring data

EPA Point 4 Site code BO0004		Point description: At the end of the chlorine contact tanks				
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
aluminium	ug/L	monthly	1	-	-	18
carbonaceous biochemical oxygen demand	mg/L	every 6 days	5	<2	<2	<2
copper	ug/L	monthly	1	-	-	2.6
diazinon	ug/L	monthly	1	-	-	<0.1
nitrogen (ammonia)	mg/L	monthly	1	-	-	0.5
nonylphenol ethoxylate	ug/L	monthly	1	-	-	<5
total suspended solids	mg/L	every 6 days	5	<2	<2	2

EPA Point 13 Site code BO0013		Point description: In the channel after the dechlorination unit				
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
faecal coliforms	CFU/100mL	every 6 days	5	1	3	5
hydrogen sulphide (unionised)	ug/L	monthly	1	-	-	<30
sea urchin fertilisation (EC50)	% Effluent/Vol	monthly	1	-	-	100

Average and percentile limits are only applied annually for routine monitoring data in Table 2

Bombo Wastewater Treatment Plant

March Pollution Monitoring Summary



EPL 2269

Summary period: 01-03-2020 to 31-03-2020

Date obtained: 06-04-2020

Date published: 15-04-2020

Licensee: Sydney Water Corporation

PO Box 399

PARRAMATTA NSW 2124

Table 1: 3 Day Geometric Mean data

EPA Point 4 Site code BO0004		Point description: At the end of the chlorine contact tanks			
pollutant	unit of measure	sampling frequency	3DGM limit	3DGM Actual	within limits
total suspended solids	mg/L	monthly	50	<2	yes

3 Day Geometric Mean (3DGM) is a way to average a set of values and is commonly used with water quality assessments which show a great deal of variability. 3DGM is calculated by multiplying the results of the analysis of three samples collected on three consecutive days and then taking the cubed root of that amount.

Table 2: Routine monitoring data

EPA Point 4 Site code BO0004		Point description: At the end of the chlorine contact tanks				
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
aluminium	ug/L	monthly	1	-	-	19
carbonaceous biochemical oxygen demand	mg/L	every 6 days	5	<2	<2	<2
copper	ug/L	monthly	1	-	-	2.1
diazinon	ug/L	monthly	1	-	-	<0.1
nitrogen (ammonia)	mg/L	monthly	1	-	-	8.6
nonylphenol ethoxylate	ug/L	monthly	1	-	-	<5
total suspended solids	mg/L	every 6 days	5	<2	<2	3

EPA Point 13 Site code BO0013		Point description: In the channel after the dechlorination unit				
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
faecal coliforms	CFU/100mL	every 6 days	5	1	3	8
hydrogen sulphide (unionised)	ug/L	monthly	1	-	-	<30
sea urchin fertilisation (EC50)	% Effluent/Vol	monthly	1	-	-	100

Average and percentile limits are only applied annually for routine monitoring data in Table 2

Bombo Wastewater Treatment Plant

February Pollution Monitoring Summary



EPL 2269

Summary period: 01-02-2020 to 29-02-2020

Date obtained: 20-03-2020

Date published: 27-03-2020

Licensee: Sydney Water Corporation

PO Box 399

PARRAMATTA NSW 2124

Table 1: 3 Day Geometric Mean data

EPA Point 4 Site code BO0004		Point description: At the end of the chlorine contact tanks			
pollutant	unit of measure	sampling frequency	3DGM limit	3DGM Actual	within limits
total suspended solids	mg/L	monthly	50	11	yes

3 Day Geometric Mean (3DGM) is a way to average a set of values and is commonly used with water quality assessments which show a great deal of variability. 3DGM is calculated by multiplying the results of the analysis of three samples collected on three consecutive days and then taking the cubed root of that amount.

Table 2: Routine monitoring data

EPA Point 4 Site code BO0004		Point description: At the end of the chlorine contact tanks				
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
aluminium	ug/L	monthly	1	-	-	36
carbonaceous biochemical oxygen demand	mg/L	every 6 days	5	<2	4	10
copper	ug/L	monthly	1	-	-	4.8
diazinon	ug/L	monthly	1	-	-	<0.1
nitrogen (ammonia)	mg/L	monthly	1	-	-	37.2
nonylphenol ethoxylate	ug/L	monthly	1	-	-	12
total suspended solids	mg/L	every 6 days	5	<2	11	41

EPA Point 13 Site code BO0013		Point description: In the channel after the dechlorination unit				
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
faecal coliforms	CFU/100mL	every 6 days	5	<1	20002	100,000
hydrogen sulphide (unionised)	ug/L	monthly	1	-	-	<30
sea urchin fertilisation (EC50)	% Effluent/Vol	monthly	1	-	-	100

Average and percentile limits are only applied annually for routine monitoring data in Table 2

Bombo Wastewater Treatment Plant

January Pollution Monitoring Summary



EPL 2269

Summary period: 01-01-2020 to 31-01-2020

Date obtained: 05-02-2020

Date published: 14-02-2020

Licensee: Sydney Water Corporation

PO Box 399

PARRAMATTA NSW 2124

Table 1: 3 Day Geometric Mean data

EPA Point 4 Site code BO0004		Point description: At the end of the chlorine contact tanks			
pollutant	unit of measure	sampling frequency	3DGM limit	3DGM Actual	within limits
total suspended solids	mg/L	monthly	50	4	yes

3 Day Geometric Mean (3DGM) is a way to average a set of values and is commonly used with water quality assessments which show a great deal of variability. 3DGM is calculated by multiplying the results of the analysis of three samples collected on three consecutive days and then taking the cubed root of that amount.

Table 2: Routine monitoring data

EPA Point 4 Site code BO0004		Point description: At the end of the chlorine contact tanks				
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
aluminium	ug/L	monthly	1	-	-	42
carbonaceous biochemical oxygen demand	mg/L	every 6 days	5	<2	6	12
copper	ug/L	monthly	1	-	-	3.2
diazinon	ug/L	monthly	1	-	-	<0.1
nitrogen (ammonia)	mg/L	monthly	1	-	-	13.2
nonylphenol ethoxylate	ug/L	monthly	1	-	-	<5
total suspended solids	mg/L	every 6 days	5	5	7	9

EPA Point 13 Site code BO0013		Point description: In the channel after the dechlorination unit				
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
faecal coliforms	CFU/100mL	every 6 days	5	3	135	610
hydrogen sulphide (unionised)	ug/L	monthly	1	-	-	<30
sea urchin fertilisation (EC50)	% Effluent/Vol	monthly	1	-	-	100

Average and percentile limits are only applied annually for routine monitoring data in Table 2

Bombo Wastewater Treatment Plant

December Pollution Monitoring Summary



EPL 2269

Summary period: 01-12-2019 to 31-12-2019

Date obtained: 06-01-2020

Date published: 10-01-2020

Licensee: Sydney Water Corporation

PO Box 399

PARRAMATTA NSW 2124

Table 1: 3 Day Geometric Mean data

EPA Point 4 Site code BO0004		Point description: At the end of the chlorine contact tanks			
pollutant	unit of measure	sampling frequency	3DGM limit	3DGM Actual	within limits
total suspended solids	mg/L	monthly	50	<2	yes

3 Day Geometric Mean (3DGM) is a way to average a set of values and is commonly used with water quality assessments which show a great deal of variability. 3DGM is calculated by multiplying the results of the analysis of three samples collected on three consecutive days and then taking the cubed root of that amount.

Table 2: Routine monitoring data

EPA Point 4 Site code BO0004		Point description: At the end of the chlorine contact tanks				
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
aluminium	ug/L	monthly	1	-	-	21
carbonaceous biochemical oxygen demand	mg/L	every 6 days	5	<2	<2	<2
copper	ug/L	monthly	1	-	-	3.4
diazinon	ug/L	monthly	1	-	-	<0.1
nitrogen (ammonia)	mg/L	monthly	1	-	-	<0.1
nonylphenol ethoxylate	ug/L	monthly	1	-	-	38
total suspended solids	mg/L	every 6 days	5	<2	2	6

EPA Point 13 Site code BO0013		Point description: In the channel after the dechlorination unit				
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
faecal coliforms	CFU/100mL	every 6 days	5	<1	2	3
hydrogen sulphide (unionised)	ug/L	monthly	1	-	-	<30
sea urchin fertilisation (EC50)	% Effluent/Vol	monthly	1	-	-	100

Average and percentile limits are only applied annually for routine monitoring data in Table 2

Bombo Wastewater Treatment Plant

November Pollution Monitoring Summary



EPL 2269

Summary period: 01-11-2019 to 30-11-2019

Date obtained: 06-12-2019

Date published: 12-12-2019

Licensee: Sydney Water Corporation

PO Box 399

PARRAMATTA NSW 2124

Table 1: 3 Day Geometric Mean data

EPA Point 4 Site code BO0004		Point description: At the end of the chlorine contact tanks			
pollutant	unit of measure	sampling frequency	3DGM limit	3DGM Actual	within limits
total suspended solids	mg/L	monthly	50	<2	yes

3 Day Geometric Mean (3DGM) is a way to average a set of values and is commonly used with water quality assessments which show a great deal of variability. 3DGM is calculated by multiplying the results of the analysis of three samples collected on three consecutive days and then taking the cubed root of that amount.

Table 2: Routine monitoring data

EPA Point 4 Site code BO0004		Point description: At the end of the chlorine contact tanks				
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
aluminium	ug/L	monthly	1	-	-	19
carbonaceous biochemical oxygen demand	mg/L	every 6 days	5	<2	<2	<2
copper	ug/L	monthly	1	-	-	2.8
diazinon	ug/L	monthly	1	-	-	<0.1
nitrogen (ammonia)	mg/L	monthly	1	-	-	0.1
nonylphenol ethoxylate	ug/L	monthly	1	-	-	<5
total suspended solids	mg/L	every 6 days	5	<2	<2	<2

EPA Point 13 Site code BO0013		Point description: In the channel after the dechlorination unit				
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
faecal coliforms	CFU/100mL	every 6 days	5	<1	<1	1
hydrogen sulphide (unionised)	ug/L	monthly	1	-	-	<30
sea urchin fertilisation (EC50)	% Effluent/Vol	monthly	1	-	-	100

Average and percentile limits are only applied annually for routine monitoring data in Table 2

Bombo Wastewater Treatment Plant

October Pollution Monitoring Summary



EPL 2269

Summary period: 01-10-2019 to 31-10-2019

Date obtained: 12-11-2019

Date published: 22-11-2019

Licensee: Sydney Water Corporation

PO Box 399

PARRAMATTA NSW 2124

Table 1: 3 Day Geometric Mean data

EPA Point 4 Site code BO0004		Point description: At the end of the chlorine contact tanks			
pollutant	unit of measure	sampling frequency	3DGM limit	3DGM Actual	within limits
total suspended solids	mg/L	monthly	50	2	yes

3 Day Geometric Mean (3DGM) is a way to average a set of values and is commonly used with water quality assessments which show a great deal of variability. 3DGM is calculated by multiplying the results of the analysis of three samples collected on three consecutive days and then taking the cubed root of that amount.

Table 2: Routine monitoring data

EPA Point 4 Site code BO0004		Point description: At the end of the chlorine contact tanks				
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
aluminium	ug/L	monthly	1	-	-	20
carbonaceous biochemical oxygen demand	mg/L	every 6 days	5	<2	<2	<2
copper	ug/L	monthly	1	-	-	2.7
diazinon	ug/L	monthly	1	-	-	<0.1
nitrogen (ammonia)	mg/L	monthly	1	-	-	1
nonylphenol ethoxylate	ug/L	monthly	1	-	-	<5
total suspended solids	mg/L	every 6 days	5	<2	<2	3

EPA Point 13 Site code BO0013		Point description: In the channel after the dechlorination unit				
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
faecal coliforms	CFU/100mL	every 6 days	6	<1	<1	2
hydrogen sulphide (unionised)	ug/L	monthly	1	-	-	<30
sea urchin fertilisation (EC50)	% Effluent/Vol	monthly	1	-	-	100

Average and percentile limits are only applied annually for routine monitoring data in Table 2

Bombo Wastewater Treatment Plant

September Pollution Monitoring Summary



EPL 2269

Summary period: 01-09-2019 to 30-09-2019

Date obtained: 10-10-2019

Date published: 15-10-2019

Licensee: Sydney Water Corporation

PO Box 399

PARRAMATTA NSW 2124

Table 1: 3 Day Geometric Mean data

EPA Point 4 Site code BO0004		Point description: At the end of the chlorine contact tanks			
pollutant	unit of measure	sampling frequency	3DGM limit	3DGM Actual	within limits
total suspended solids	mg/L	monthly	50	2	yes

3 Day Geometric Mean (3DGM) is a way to average a set of values and is commonly used with water quality assessments which show a great deal of variability. 3DGM is calculated by multiplying the results of the analysis of three samples collected on three consecutive days and then taking the cubed root of that amount.

Table 2: Routine monitoring data

EPA Point 4 Site code BO0004		Point description: At the end of the chlorine contact tanks				
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
aluminium	ug/L	monthly	1	-	-	22
carbonaceous biochemical oxygen demand	mg/L	every 6 days	5	<2	<2	5
copper	ug/L	monthly	1	-	-	2.1
diazinon	ug/L	monthly	1	-	-	<0.1
nitrogen (ammonia)	mg/L	monthly	1	-	-	0.5
nonylphenol ethoxylate	ug/L	monthly	1	-	-	<5
total suspended solids	mg/L	every 6 days	5	<2	3	15

EPA Point 13 Site code BO0013		Point description: In the channel after the dechlorination unit				
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
faecal coliforms	CFU/100mL	every 6 days	5	<1	24	120
hydrogen sulphide (unionised)	ug/L	monthly	1	-	-	<30
sea urchin fertilisation (EC50)	% Effluent/Vol	monthly	1	-	-	100

Average and percentile limits are only applied annually for routine monitoring data in Table 2

Bombo Wastewater Treatment Plant

August Pollution Monitoring Summary



EPL 2269

Summary period: 01-08-2019 to 31-08-2019

Date obtained: 09-09-2019

Date published: 16-09-2019

Licensee: Sydney Water Corporation

PO Box 399

PARRAMATTA NSW 2124

Table 1: 3 Day Geometric Mean data

EPA Point 4 Site code BO0004		Point description: At the end of the chlorine contact tanks			
pollutant	unit of measure	sampling frequency	3DGM limit	3DGM Actual	within limits
total suspended solids	mg/L	monthly	50	<2	yes

3 Day Geometric Mean (3DGM) is a way to average a set of values and is commonly used with water quality assessments which show a great deal of variability. 3DGM is calculated by multiplying the results of the analysis of three samples collected on three consecutive days and then taking the cubed root of that amount.

Table 2: Routine monitoring data

EPA Point 4 Site code BO0004		Point description: At the end of the chlorine contact tanks				
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
aluminium	ug/L	monthly	1	-	-	22
carbonaceous biochemical oxygen demand	mg/L	every 6 days	6	<2	<2	<2
copper	ug/L	monthly	1	-	-	2.7
diazinon	ug/L	monthly	1	-	-	<0.1
nitrogen (ammonia)	mg/L	monthly	1	-	-	3
nonylphenol ethoxylate	ug/L	monthly	1	-	-	12
total suspended solids	mg/L	every 6 days	6	<2	<2	4

EPA Point 13 Site code BO0013		Point description: In the channel after the dechlorination unit				
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
faecal coliforms	CFU/100mL	every 6 days	5	<1	<1	<1
hydrogen sulphide (unionised)	ug/L	monthly	1	-	-	<30
sea urchin fertilisation (EC50)	% Effluent/Vol	monthly	1	-	-	100

Average and percentile limits are only applied annually for routine monitoring data in Table 2

Bombo Wastewater Treatment Plant

July Pollution Monitoring Summary



EPL 2269

Summary period: 01-07-2019 to 31-07-2019

Date obtained: 07-08-2019

Date published: 17-08-2019

Licensee: Sydney Water Corporation

PO Box 399

PARRAMATTA NSW 2124

Table 1: 3 Day Geometric Mean data

EPA Point 4 Site code BO0004		Point description: At the end of the chlorine contact tanks			
pollutant	unit of measure	sampling frequency	3DGM limit	3DGM Actual	within limits
total suspended solids	mg/L	monthly	50	<2	yes

3 Day Geometric Mean (3DGM) is a way to average a set of values and is commonly used with water quality assessments which show a great deal of variability. 3DGM is calculated by multiplying the results of the analysis of three samples collected on three consecutive days and then taking the cubed root of that amount.

Table 2: Routine monitoring data

EPA Point 4 Site code BO0004		Point description: At the end of the chlorine contact tanks				
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
aluminium	ug/L	monthly	1	-	-	17
carbonaceous biochemical oxygen demand	mg/L	every 6 days	5	<2	<2	<2
copper	ug/L	monthly	1	-	-	3.2
diazinon	ug/L	monthly	1	-	-	<0.1
nitrogen (ammonia)	mg/L	monthly	1	-	-	0.2
nonylphenol ethoxylate	ug/L	monthly	1	-	-	<5
total suspended solids	mg/L	every 6 days	5	<2	<2	<2

EPA Point 13 Site code BO0013		Point description: In the channel after the dechlorination unit				
pollutant	unit of measure	sampling frequency	number of samples	minimum result	mean result	maximum result
faecal coliforms	CFU/100mL	every 6 days	5	<1	<1	1
hydrogen sulphide (unionised)	ug/L	monthly	1	-	-	<30
sea urchin fertilisation (EC50)	% Effluent/Vol	monthly	1	-	-	100

Average and percentile limits are only applied annually for routine monitoring data in Table 2