

Liverpool Wastewater Treatment Plant

June Pollution Monitoring Summary

EPL 372



Summary period: 01-06-2020 to 30-06-2020

Date obtained: 01-07-2020

Date published: 14-07-2020

Licensee: Sydney Water Corporation

PO Box 399

PARRAMATTA NSW 2124

Table 1: 100 percentile data

EPA Point 15 Site code LP0015 Overflow Point		Point description: Effluent diversion structure at Chipping Norton			
pollutant	unit of measure	sampling frequency	100 percentile limit	100 percentile actual	within limits
carbonaceous biochemical oxygen demand	mg/L	on bypass	100	12	yes
total suspended solids	mg/L	on bypass	100	14	yes

Under Environment Protection Licence 372 conditions, as set by the NSW Environment Protection Authority, the 100 percentile limits are allowed to be exceeded during wet weather.

Table 2: Routine monitoring data

EPA Point 15 Site code LP0015 Overflow Point		Point description: Effluent diversion structure at Chipping Norton				
pollutant	unit of measure	sampling frequency	number of samples	minimum results	mean results	maximum results
carbonaceous biochemical oxygen demand	mg/L	on bypass	1	-	-	12
faecal coliforms	CFU/100mL	on bypass	1	-	-	740,000
total suspended solids	mg/L	on bypass	1	-	-	14

Table 1: 100 percentile data

EPA Point 76 Site code LP0076		Point description: Chlorine contact tank adjacent to reuse pumps			
pollutant	unit of measure	sampling frequency	100 percentile limit	100 percentile actual	within limits
carbonaceous biochemical oxygen demand	mg/L	monthly during discharge	100	<2	yes
total suspended solids	mg/L	monthly during discharge	100	4	yes

100 percentile means that 100 % of samples (or all samples) taken must not exceed the limit for that pollutant.

Table 2: Routine monitoring data

EPA Point 76 Site code LP0076		Point description: Chlorine contact tank adjacent to reuse pumps				
pollutant	unit of measure	sampling frequency	number of samples	minimum results	mean results	maximum results
carbonaceous biochemical oxygen demand	mg/L	monthly during discharge	1	-	-	<2
total suspended solids	mg/L	monthly during discharge	1	-	-	4

Average and percentile limits are only applied annually for routine monitoring data in Table 2.

Liverpool Wastewater Treatment Plant

May Pollution Monitoring Summary

EPL 372



Summary period: 01-05-2020 to 31-05-2020

Date obtained: 09-06-2020

Date published: 17-06-2020

Licensee: Sydney Water Corporation

PO Box 399

PARRAMATTA NSW 2124

Table 1: 100 percentile data

EPA Point 15 Site code LP0015 Overflow Point		Point description: Effluent diversion structure at Chipping Norton			
pollutant	unit of measure	sampling frequency	100 percentile limit	100 percentile actual	within limits
carbonaceous biochemical oxygen demand	mg/L	on bypass	100	54	yes
total suspended solids	mg/L	on bypass	100	30	yes

Under Environment Protection Licence 372 conditions, as set by the NSW Environment Protection Authority, the 100 percentile limits are allowed to be exceeded during wet weather.

Table 2: Routine monitoring data

EPA Point 15 Site code LP0015 Overflow Point		Point description: Effluent diversion structure at Chipping Norton				
pollutant	unit of measure	sampling frequency	number of samples	minimum results	mean results	maximum results
carbonaceous biochemical oxygen demand	mg/L	on bypass	4	17	37	54
faecal coliforms	CFU/100mL	on bypass	4	45	1142511	3,500,000
total suspended solids	mg/L	on bypass	4	16	26	30

Table 1: 100 percentile data

EPA Point 76 Site code LP0076		Point description: Chlorine contact tank adjacent to reuse pumps			
pollutant	unit of measure	sampling frequency	100 percentile limit	100 percentile actual	within limits
carbonaceous biochemical oxygen demand	mg/L	monthly during discharge	100	<2	yes
total suspended solids	mg/L	monthly during discharge	100	9	yes

100 percentile means that 100 % of samples (or all samples) taken must not exceed the limit for that pollutant.

Table 2: Routine monitoring data

EPA Point 76 Site code LP0076		Point description: Chlorine contact tank adjacent to reuse pumps				
pollutant	unit of measure	sampling frequency	number of samples	minimum results	mean results	maximum results
carbonaceous biochemical oxygen demand	mg/L	monthly during discharge	1	-	-	<2
total suspended solids	mg/L	monthly during discharge	1	-	-	9

Average and percentile limits are only applied annually for routine monitoring data in Table 2.

Liverpool Wastewater Treatment Plant

May Pollution Monitoring Summary

EPL 372



Summary period: 01-05-2020 to 31-05-2020

Date obtained: 09-06-2020

Date published: 14-06-2020

Licensee: Sydney Water Corporation

PO Box 399

PARRAMATTA NSW 2124

Table 1: 100 percentile data

EPA Point 81 Site code LP0081 Overflow Point		Point description: Overflow chamber downstream of chlorine contact tank			
pollutant	unit of measure	sampling frequency	100 percentile limit	100 percentile actual	within limits
carbonaceous biochemical oxygen demand	mg/L	on bypass	100	33	yes
total suspended solids	mg/L	on bypass	100	16	yes

Under Environment Protection Licence 372 conditions, as set by the NSW Environment Protection Authority, the 100 percentile limits are allowed to be exceeded during wet weather.

Table 2: Routine monitoring data

EPA Point 81 Site code LP0081 Overflow Point		Point description: Overflow chamber downstream of chlorine contact tank				
pollutant	unit of measure	sampling frequency	number of samples	minimum results	mean results	maximum results
carbonaceous biochemical oxygen demand	mg/L	on bypass	1	-	-	33
faecal coliforms	CFU/100mL	on bypass	1	-	-	25,000
total suspended solids	mg/L	on bypass	1	-	-	16

Liverpool Wastewater Treatment Plant

April Pollution Monitoring Summary

EPL 372



Summary period: 01-04-2020 to 30-04-2020

Date obtained: 14-04-2020

Date published: 27-04-2020

Licensee: Sydney Water Corporation

PO Box 399

PARRAMATTA NSW 2124

Table 1: 100 percentile data

EPA Point 15 Site code LP0015 Overflow Point		Point description: Effluent diversion structure at Chipping Norton			
pollutant	unit of measure	sampling frequency	100 percentile limit	100 percentile actual	within limits
carbonaceous biochemical oxygen demand	mg/L	on bypass	100	33	yes
total suspended solids	mg/L	on bypass	100	20	yes

Under Environment Protection Licence 372 conditions, as set by the NSW Environment Protection Authority, the 100 percentile limits are allowed to be exceeded during wet weather.

Table 2: Routine monitoring data

EPA Point 15 Site code LP0015 Overflow Point		Point description: Effluent diversion structure at Chipping Norton				
pollutant	unit of measure	sampling frequency	number of samples	minimum results	mean results	maximum results
carbonaceous biochemical oxygen demand	mg/L	on bypass	3	30	32	33
faecal coliforms	CFU/100mL	on bypass	3	660	2100220	3,800,000
total suspended solids	mg/L	on bypass	3	17	19	20

Table 1: 100 percentile data

EPA Point 76 Site code LP0076		Point description: Chlorine contact tank adjacent to reuse pumps			
pollutant	unit of measure	sampling frequency	100 percentile limit	100 percentile actual	within limits
carbonaceous biochemical oxygen demand	mg/L	monthly during discharge	100	3	yes
total suspended solids	mg/L	monthly during discharge	100	4	yes

100 percentile means that 100 % of samples (or all samples) taken must not exceed the limit for that pollutant.

Table 2: Routine monitoring data

EPA Point 76 Site code LP0076		Point description: Chlorine contact tank adjacent to reuse pumps				
pollutant	unit of measure	sampling frequency	number of samples	minimum results	mean results	maximum results
carbonaceous biochemical oxygen demand	mg/L	monthly during discharge	1	-	-	3
total suspended solids	mg/L	monthly during discharge	1	-	-	4

Average and percentile limits are only applied annually for routine monitoring data in Table 2.

Liverpool Wastewater Treatment Plant

March Pollution Monitoring Summary

EPL 372



Summary period: 01-03-2020 to 31-03-2020

Date obtained: 07-04-2020

Date published: 15-04-2020

Licensee: Sydney Water Corporation

PO Box 399

PARRAMATTA NSW 2124

Table 1: 100 percentile data

EPA Point 15 Site code LP0015 Overflow Point		Point description: Effluent diversion structure at Chipping Norton			
pollutant	unit of measure	sampling frequency	100 percentile limit	100 percentile actual	within limits
carbonaceous biochemical oxygen demand	mg/L	on bypass	100	190	no ²
total suspended solids	mg/L	on bypass	100	140	no ²

²Under Environment Protection Licence 372 conditions, as set by the NSW Environment Protection Authority, the 100 percentile limits are allowed to be exceeded during wet weather.

Table 2: Routine monitoring data

EPA Point 15 Site code LP0015 Overflow Point		Point description: Effluent diversion structure at Chipping Norton				
pollutant	unit of measure	sampling frequency	number of samples	minimum results	mean results	maximum results
carbonaceous biochemical oxygen demand	mg/L	on bypass	11	17	50	190
faecal coliforms	CFU/100mL	on bypass	11	520,000	2058182	5,400,000
total suspended solids	mg/L	on bypass	11	14	48	140

Table 1: 100 percentile data

EPA Point 76 Site code LP0076		Point description: Chlorine contact tank adjacent to reuse pumps			
pollutant	unit of measure	sampling frequency	100 percentile limit	100 percentile actual	within limits
carbonaceous biochemical oxygen demand	mg/L	monthly during discharge	100	3	yes
total suspended solids	mg/L	monthly during discharge	100	3	yes

100 percentile means that 100 % of samples (or all samples) taken must not exceed the limit for that pollutant.

Table 2: Routine monitoring data

EPA Point 76 Site code LP0076		Point description: Chlorine contact tank adjacent to reuse pumps				
pollutant	unit of measure	sampling frequency	number of samples	minimum results	mean results	maximum results
carbonaceous biochemical oxygen demand	mg/L	monthly during discharge	1	-	-	3
total suspended solids	mg/L	monthly during discharge	1	-	-	3

Average and percentile limits are only applied annually for routine monitoring data in Table 2.

Liverpool Wastewater Treatment Plant

February Pollution Monitoring Summary

EPL 372



Summary period: 01-02-2020 to 29-02-2020

Date obtained: 13-03-2020

Date published: 27-03-2020

Licensee: Sydney Water Corporation

PO Box 399

PARRAMATTA NSW 2124

Table 1: 100 percentile data

EPA Point 15 Site code LP0015 Overflow Point		Point description: Effluent diversion structure at Chipping Norton			
pollutant	unit of measure	sampling frequency	100 percentile limit	100 percentile actual	within limits
carbonaceous biochemical oxygen demand	mg/L	on bypass	100	150	no ²
total suspended solids	mg/L	on bypass	100	56	yes

²Under Environment Protection Licence 372 conditions, as set by the NSW Environment Protection Authority, the 100 percentile limits are allowed to be exceeded during wet weather.

Table 2: Routine monitoring data

EPA Point 15 Site code LP0015 Overflow Point		Point description: Effluent diversion structure at Chipping Norton				
pollutant	unit of measure	sampling frequency	number of samples	minimum results	mean results	maximum results
carbonaceous biochemical oxygen demand	mg/L	on bypass	11	10	43	150
faecal coliforms	CFU/100mL	on bypass	11	240	738653	1,600,000
total suspended solids	mg/L	on bypass	11	20	32	56

Table 1: 100 percentile data

EPA Point 76 Site code LP0076		Point description: Chlorine contact tank adjacent to reuse pumps			
pollutant	unit of measure	sampling frequency	100 percentile limit	100 percentile actual	within limits
carbonaceous biochemical oxygen demand	mg/L	monthly during discharge	100	3	yes
total suspended solids	mg/L	monthly during discharge	100	14	yes

100 percentile means that 100 % of samples (or all samples) taken must not exceed the limit for that pollutant.

Table 2: Routine monitoring data

EPA Point 76 Site code LP0076		Point description: Chlorine contact tank adjacent to reuse pumps				
pollutant	unit of measure	sampling frequency	number of samples	minimum results	mean results	maximum results
carbonaceous biochemical oxygen demand	mg/L	monthly during discharge	1	-	-	3
total suspended solids	mg/L	monthly during discharge	1	-	-	14

Average and percentile limits are only applied annually for routine monitoring data in Table 2.

Liverpool Wastewater Treatment Plant

February Pollution Monitoring Summary

EPL 372



Summary period: 01-02-2020 to 29-02-2020

Date obtained: 13-03-2020

Date published: 27-03-2020

Licensee: Sydney Water Corporation

PO Box 399

PARRAMATTA NSW 2124

Table 1: 100 percentile data

EPA Point 81 Site code LP0081 Overflow Point		Point description: Overflow chamber downstream of chlorine contact tank			
pollutant	unit of measure	sampling frequency	100 percentile limit	100 percentile actual	within limits
carbonaceous biochemical oxygen demand	mg/L	on bypass	100	20	yes
total suspended solids	mg/L	on bypass	100	49	yes

Under Environment Protection Licence 372 conditions, as set by the NSW Environment Protection Authority, the 100 percentile limits are allowed to be exceeded during wet weather.

Table 2: Routine monitoring data

EPA Point 81 Site code LP0081 Overflow Point		Point description: Overflow chamber downstream of chlorine contact tank				
pollutant	unit of measure	sampling frequency	number of samples	minimum results	mean results	maximum results
carbonaceous biochemical oxygen demand	mg/L	on bypass	5	11	14	20
faecal coliforms	CFU/100mL	on bypass	5	1	137896	670,000
total suspended solids	mg/L	on bypass	5	18	36	49

Liverpool Wastewater Treatment Plant

January Pollution Monitoring Summary

EPL 372



Summary period: 01-01-2020 to 31-01-2020

Date obtained: 24-01-2020

Date published: 03-02-2020

Licensee: Sydney Water Corporation

PO Box 399

PARRAMATTA NSW 2124

Table 1: 100 percentile data

EPA Point 15 Site code LP0015 Overflow Point		Point description: Effluent diversion structure at Chipping Norton			
pollutant	unit of measure	sampling frequency	100 percentile limit	100 percentile actual	within limits
carbonaceous biochemical oxygen demand	mg/L	on bypass	100	9	yes
total suspended solids	mg/L	on bypass	100	36	yes

Under Environment Protection Licence 372 conditions, as set by the NSW Environment Protection Authority, the 100 percentile limits are allowed to be exceeded during wet weather.

Table 2: Routine monitoring data

EPA Point 15 Site code LP0015 Overflow Point		Point description: Effluent diversion structure at Chipping Norton				
pollutant	unit of measure	sampling frequency	number of samples	minimum results	mean results	maximum results
carbonaceous biochemical oxygen demand	mg/L	on bypass	1	-	-	9
faecal coliforms	CFU/100mL	on bypass	1	-	-	80
total suspended solids	mg/L	on bypass	1	-	-	36

Table 1: 100 percentile data

EPA Point 76 Site code LP0076		Point description: Chlorine contact tank adjacent to reuse pumps			
pollutant	unit of measure	sampling frequency	100 percentile limit	100 percentile actual	within limits
carbonaceous biochemical oxygen demand	mg/L	monthly during discharge	100	<2	yes
total suspended solids	mg/L	monthly during discharge	100	4	yes

100 percentile means that 100 % of samples (or all samples) taken must not exceed the limit for that pollutant.

Table 2: Routine monitoring data

EPA Point 76 Site code LP0076		Point description: Chlorine contact tank adjacent to reuse pumps				
pollutant	unit of measure	sampling frequency	number of samples	minimum results	mean results	maximum results
carbonaceous biochemical oxygen demand	mg/L	monthly during discharge	1	-	-	<2
total suspended solids	mg/L	monthly during discharge	1	-	-	4

Average and percentile limits are only applied annually for routine monitoring data in Table 2.

Liverpool Wastewater Treatment Plant

December Pollution Monitoring Summary

EPL 372



Summary period: 01-12-2019 to 31-12-2019

Date obtained: 12-12-2019

Date published: 02-01-2020

Licensee: Sydney Water Corporation

PO Box 399

PARRAMATTA NSW 2124

Table 1: 100 percentile data

EPA Point 76 Site code LP0076		Point description: Chlorine contact tank adjacent to reuse pumps			
pollutant	unit of measure	sampling frequency	100 percentile limit	100 percentile actual	within limits
carbonaceous biochemical oxygen demand	mg/L	monthly during discharge	100	<2	yes
total suspended solids	mg/L	monthly during discharge	100	5	yes

100 percentile means that 100 % of samples (or all samples) taken must not exceed the limit for that pollutant.

Table 2: Routine monitoring data

EPA Point 76 Site code LP0076		Point description: Chlorine contact tank adjacent to reuse pumps				
pollutant	unit of measure	sampling frequency	number of samples	minimum results	mean results	maximum results
carbonaceous biochemical oxygen demand	mg/L	monthly during discharge	1	-	-	<2
total suspended solids	mg/L	monthly during discharge	1	-	-	5

Average and percentile limits are only applied annually for routine monitoring data in Table 2.

Liverpool Wastewater Treatment Plant

November Pollution Monitoring Summary

EPL 372



Summary period: 01-11-2019 to 30-11-2019

Date obtained: 13-11-2019

Date published: 27-11-2019

Licensee: Sydney Water Corporation

PO Box 399

PARRAMATTA NSW 2124

Table 1: 100 percentile data

EPA Point 76 Site code LP0076		Point description: Chlorine contact tank adjacent to reuse pumps			
pollutant	unit of measure	sampling frequency	100 percentile limit	100 percentile actual	within limits
carbonaceous biochemical oxygen demand	mg/L	monthly during discharge	100	<2	yes
total suspended solids	mg/L	monthly during discharge	100	4	yes

100 percentile means that 100 % of samples (or all samples) taken must not exceed the limit for that pollutant.

Table 2: Routine monitoring data

EPA Point 76 Site code LP0076		Point description: Chlorine contact tank adjacent to reuse pumps				
pollutant	unit of measure	sampling frequency	number of samples	minimum results	mean results	maximum results
carbonaceous biochemical oxygen demand	mg/L	monthly during discharge	1	-	-	<2
total suspended solids	mg/L	monthly during discharge	1	-	-	4

Average and percentile limits are only applied annually for routine monitoring data in Table 2.

Liverpool Wastewater Treatment Plant

October Pollution Monitoring Summary

EPL 372



Summary period: 01-10-2019 to 31-10-2019

Date obtained: 15-10-2019

Date published: 29-10-2019

Licensee: Sydney Water Corporation

PO Box 399

PARRAMATTA NSW 2124

Table 1: 100 percentile data

EPA Point 76 Site code LP0076		Point description: Chlorine contact tank adjacent to reuse pumps			
pollutant	unit of measure	sampling frequency	100 percentile limit	100 percentile actual	within limits
carbonaceous biochemical oxygen demand	mg/L	monthly during discharge	100	<2	yes
total suspended solids	mg/L	monthly during discharge	100	2	yes

100 percentile means that 100 % of samples (or all samples) taken must not exceed the limit for that pollutant.

Table 2: Routine monitoring data

EPA Point 76 Site code LP0076		Point description: Chlorine contact tank adjacent to reuse pumps				
pollutant	unit of measure	sampling frequency	number of samples	minimum results	mean results	maximum results
carbonaceous biochemical oxygen demand	mg/L	monthly during discharge	1	-	-	<2
total suspended solids	mg/L	monthly during discharge	1	-	-	2

Average and percentile limits are only applied annually for routine monitoring data in Table 2.

Liverpool Wastewater Treatment Plant

September Pollution Monitoring Summary

EPL 372



Summary period: 01-09-2019 to 30-09-2019

Date obtained: 26-09-2019

Date published: 08-10-2019

Licensee: Sydney Water Corporation

PO Box 399

PARRAMATTA NSW 2124

Table 1: 100 percentile data

EPA Point 15 Site code LP0015 Overflow Point		Point description: Effluent diversion structure at Chipping Norton			
pollutant	unit of measure	sampling frequency	100 percentile limit	100 percentile actual	within limits
carbonaceous biochemical oxygen demand	mg/L	on bypass	100	130	no ²
total suspended solids	mg/L	on bypass	100	53	yes

²Under Environment Protection Licence 372 conditions, as set by the NSW Environment Protection Authority, the 100 percentile limits are allowed to be exceeded during wet weather.

Table 2: Routine monitoring data

EPA Point 15 Site code LP0015 Overflow Point		Point description: Effluent diversion structure at Chipping Norton				
pollutant	unit of measure	sampling frequency	number of samples	minimum results	mean results	maximum results
carbonaceous biochemical oxygen demand	mg/L	on bypass	4	16	49	130
faecal coliforms	CFU/100mL	on bypass	4	36	275903	1,100,000
total suspended solids	mg/L	on bypass	4	26	38	53

Table 1: 100 percentile data

EPA Point 76 Site code LP0076		Point description: Chlorine contact tank adjacent to reuse pumps			
pollutant	unit of measure	sampling frequency	100 percentile limit	100 percentile actual	within limits
carbonaceous biochemical oxygen demand	mg/L	monthly during discharge	100	2	yes
total suspended solids	mg/L	monthly during discharge	100	10	yes

100 percentile means that 100 % of samples (or all samples) taken must not exceed the limit for that pollutant.

Table 2: Routine monitoring data

EPA Point 76 Site code LP0076		Point description: Chlorine contact tank adjacent to reuse pumps				
pollutant	unit of measure	sampling frequency	number of samples	minimum results	mean results	maximum results
carbonaceous biochemical oxygen demand	mg/L	monthly during discharge	1	-	-	2
total suspended solids	mg/L	monthly during discharge	1	-	-	10

Average and percentile limits are only applied annually for routine monitoring data in Table 2.

Liverpool Wastewater Treatment Plant

August Pollution Monitoring Summary

EPL 372



Summary period: 01-08-2019 to 31-08-2019

Date obtained: 14-08-2019

Date published: 04-09-2019

Licensee: Sydney Water Corporation

PO Box 399

PARRAMATTA NSW 2124

Table 1: 100 percentile data

EPA Point 76 Site code LP0076		Point description: Chlorine contact tank adjacent to reuse pumps			
pollutant	unit of measure	sampling frequency	100 percentile limit	100 percentile actual	within limits
carbonaceous biochemical oxygen demand	mg/L	monthly during discharge	100	2	yes
total suspended solids	mg/L	monthly during discharge	100	7	yes

100 percentile means that 100 % of samples (or all samples) taken must not exceed the limit for that pollutant.

Table 2: Routine monitoring data

EPA Point 76 Site code LP0076		Point description: Chlorine contact tank adjacent to reuse pumps				
pollutant	unit of measure	sampling frequency	number of samples	minimum results	mean results	maximum results
carbonaceous biochemical oxygen demand	mg/L	monthly during discharge	1	-	-	2
total suspended solids	mg/L	monthly during discharge	1	-	-	7

Average and percentile limits are only applied annually for routine monitoring data in Table 2.

Liverpool Wastewater Treatment Plant

July Pollution Monitoring Summary

EPL 372



Summary period: 01-07-2019 to 31-07-2019

Date obtained: 17-07-2019

Date published: 01-08-2019

Licensee: Sydney Water Corporation

PO Box 399

PARRAMATTA NSW 2124

Table 1: 100 percentile data

EPA Point 15 Site code LP0015 Overflow Point		Point description: Effluent diversion structure at Chipping Norton			
pollutant	unit of measure	sampling frequency	100 percentile limit	100 percentile actual	within limits
carbonaceous biochemical oxygen demand	mg/L	on bypass	100	31	yes
total suspended solids	mg/L	on bypass	100	140	no ²

²Under Environment Protection Licence 372 conditions, as set by the NSW Environment Protection Authority, the 100 percentile limits are allowed to be exceeded during wet weather.

Table 2: Routine monitoring data

EPA Point 15 Site code LP0015 Overflow Point		Point description: Effluent diversion structure at Chipping Norton				
pollutant	unit of measure	sampling frequency	number of samples	minimum results	mean results	maximum results
carbonaceous biochemical oxygen demand	mg/L	on bypass	1	-	-	31
faecal coliforms	CFU/100mL	on bypass	1	-	-	53,000
total suspended solids	mg/L	on bypass	1	-	-	140

Table 1: 100 percentile data

EPA Point 76 Site code LP0076		Point description: Chlorine contact tank adjacent to reuse pumps			
pollutant	unit of measure	sampling frequency	100 percentile limit	100 percentile actual	within limits
carbonaceous biochemical oxygen demand	mg/L	monthly during discharge	100	<2	yes
total suspended solids	mg/L	monthly during discharge	100	6	yes

100 percentile means that 100 % of samples (or all samples) taken must not exceed the limit for that pollutant.

Table 2: Routine monitoring data

EPA Point 76 Site code LP0076		Point description: Chlorine contact tank adjacent to reuse pumps				
pollutant	unit of measure	sampling frequency	number of samples	minimum results	mean results	maximum results
carbonaceous biochemical oxygen demand	mg/L	monthly during discharge	1	-	-	<2
total suspended solids	mg/L	monthly during discharge	1	-	-	6

Average and percentile limits are only applied annually for routine monitoring data in Table 2.