

Glenfield Wastewater Treatment Plant

2018-2019 Pollution Monitoring Summary

EPL 372



Summary period: 01-07-2018 to 30-06-2019

Date published: 09-09-2019

Licensee: Sydney Water Corporation

PO Box 399

PARRAMATTA NSW 2124

Table 1: 100 percentile yearly summary

EPA Point 20 Site code GF0020 Overflow Point		Point description: Overflow chamber							
pollutant	unit of measure	sampling frequency	number of samples	minimum results	mean results	maximum results	100 percentile limit	100 percentile value	within limits
carbonaceous biochemical oxygen demand	mg/L	on bypass	7	11	30	62	100	62	yes
total suspended solids	mg/L	on bypass	7	35	63	88	100	88	yes

Under Environment Protection Licence 372 conditions, as set by the NSW Environment Protection Authority, the 100 percentile limits are allowed to be exceeded during wet weather. Details of any within limit exceptions were provided in monthly reports

Table 2: Average yearly summary

EPA Point 20 Site code GF0020 Overflow Point		Point description: Overflow chamber				
pollutant	unit of measure	sampling frequency	number of samples	minimum results	mean results	maximum results
carbonaceous biochemical oxygen demand	mg/L	on bypass	7	11	30	62
faecal coliforms	CFU/100mL	on bypass	7	12	2,186,602	9,200,000
total suspended solids	mg/L	on bypass	7	35	63	88