

West Camden Wastewater Treatment Plant

2017-18 Pollution monitoring yearly limit summaries



EPL 1675

Summary period: 01-07-2017 to 30-06-2018

Date published: 14-09-2018

Licensee: Sydney Water Corporation

PO Box 399

PARRAMATTA NSW 2124

50 percentile yearly summary								
EPA Point 5 Site code WC0005		Point description: At the outlet of the chlorine contact tank						
pollutant	unit of measure	sampling frequency	number of samples	minimum result	maximum result	50 percentile limit	50 percentile value	within limits
carbonaceous biochemical oxygen demand	mg/L	every 6 days	61	<2	<2	10	<2	yes
Ceriodaphnia dubia immobilisation (EC50)	% Effluent/Vol	monthly	12	100	100	50	100	yes
nitrogen (ammonia)	mg/L	every 6 days	61	0.01	2.77	1	0.02	yes
nitrogen (total)	mg/L	every 6 days	61	4.38	8.67	10	6.12	yes
phosphorus (total)	mg/L	every 6 days	61	0.02	0.24	0.3	0.04	yes
total suspended solids	mg/L	every 6 days	61	<2	3	10	<2	yes

80 percentile yearly summary								
EPA Point 5 Site code WC0005		Point description: At the outlet of the chlorine contact tank						
pollutant	unit of measure	sampling frequency	number of samples	minimum result	maximum result	80 percentile limit	80 percentile value	within limits
faecal coliforms	CFU/100mL	every 6 days	61	<1	48	200	3	yes

West Camden Wastewater Treatment Plant

2017-18 Pollution monitoring yearly limit summaries



EPL 1675

Summary period: 01-07-2017 to 30-06-2018

Date published: 13-09-2018

Licensee: Sydney Water Corporation

PO Box 399

PARRAMATTA NSW 2124

90 percentile yearly summary								
EPA Point 5 Site code WC0005		Point description: At the outlet of the chlorine contact tank						
pollutant	unit of measure	sampling frequency	number of samples	minimum result	maximum result	90 percentile limit	90 percentile value	within limits
aluminium	ug/L	monthly	12	35	77	500	76	yes
carbonaceous biochemical oxygen demand	mg/L	every 6 days	61	<2	<2	15	<2	yes
chlorine (total residual)	mg/L	every 6 days	61	<0.04	0.04	0.1	<0.04	yes
cobalt	ug/L	monthly	12	0.3	0.5	16.5	0.5	yes
copper	ug/L	monthly	12	<0.5	2	48	1.3	yes
cyanide	ug/L	monthly	12	<5	<5	340	<5	yes
diazinon	ug/L	monthly	12	<0.1	<0.1	6.4	<0.1	yes
hydrogen sulphide (unionised)	ug/L	monthly	12	<30	39	300	<30	yes
iron	ug/L	monthly	12	25	66	6,000	62	yes
nickel	ug/L	monthly	12	1.6	3.3	14.3	3	yes
nitrogen (ammonia)	mg/L	every 6 days	61	0.01	2.77	5	0.22	yes
nitrogen (total)	mg/L	every 6 days	61	4.38	8.67	15	7.44	yes
phosphorus (total)	mg/L	every 6 days	61	0.02	0.24	1	0.09	yes
total suspended solids	mg/L	every 6 days	61	<2	3	15	<2	yes
zinc	ug/L	monthly	12	16	31	50	25	yes

West Camden Wastewater Treatment Plant

2017-18 Pollution monitoring yearly limit summaries



EPL 1675

Summary period: 01-07-2017 to 30-06-2018

Date published: 13-09-2018

Licensee: Sydney Water Corporation

PO Box 399

PARRAMATTA NSW 2124

Average yearly summary								
EPA Point 5 Site code WC0005		Point description: At the outlet of the chlorine contact tank						
pollutant	unit of measure	sampling frequency	number of samples	minimum result	maximum result	Average Limit	Average value	within limits
aluminium	ug/L	monthly	12	35	77	130	53	yes
cobalt	ug/L	monthly	12	0.3	0.5	1.8	0.4	yes
copper	ug/L	monthly	12	<0.5	2	11.6	1	yes
cyanide	ug/L	monthly	12	<5	<5	16.9	<5	yes
diazinon	ug/L	monthly	12	<0.1	<0.1	0.8	<0.1	yes
hydrogen sulphide (unionised)	ug/L	monthly	12	<30	39	70	<30	yes
iron	ug/L	monthly	12	25	66	500	41	yes
nickel	ug/L	monthly	12	1.6	3.3	11.7	2	yes
zinc	ug/L	monthly	12	16	31	40	22	yes