

Winmalee Wastewater Treatment Plant

2019-20 Pollution monitoring yearly limit summaries



EPL 1963

Summary period: 01-07-2019 to 30-06-2020

Date published: 10-08-2020

Licensee: Sydney Water Corporation

PO Box 399

PARRAMATTA NSW 2124

50 percentile yearly summary								
EPA Point 4 Site code WM0004		Point description: Downstream of the chamber prior to discharge						
pollutant	unit of measure	sampling frequency	number of samples	minimum result	maximum result	50 percentile limit	50 percentile value	within limits
carbonaceous biochemical oxygen demand	mg/L	every 6 days	61	<2	2	10	<2	yes
Ceriodaphnia dubia immobilisation (EC50)	% Effluent/Vol	monthly	12	100	100	50	100	yes
nitrogen (ammonia)	mg/L	every 6 days	61	0.01	5.71	2	0.19	yes
nitrogen (total)	mg/L	every 6 days	61	5.42	12.8	10	8.47	yes
phosphorus (total)	mg/L	every 6 days	61	0.05	0.47	2	0.14	yes
total suspended solids	mg/L	every 6 days	61	<2	12	10	<2	yes

80 percentile yearly summary								
EPA Point 4 Site code WM0004		Point description: Downstream of the chamber prior to discharge						
pollutant	unit of measure	sampling frequency	number of samples	minimum result	maximum result	80 percentile limit	80 percentile value	within limits
faecal coliforms	CFU/100mL	every 6 days	61	<1	4,000	200	4	yes

Winmalee Wastewater Treatment Plant

2019-20 Pollution monitoring yearly limit summaries



EPL 1963

Summary period: 01-07-2019 to 30-06-2020

Date published: 10-08-2020

Licensee: Sydney Water Corporation

PO Box 399

PARRAMATTA NSW 2124

90 percentile yearly summary								
EPA Point 4 Site code WM0004		Point description: Downstream of the chamber prior to discharge						
pollutant	unit of measure	sampling frequency	number of samples	minimum result	maximum result	90 percentile limit	90 percentile value	within limits
aluminium	ug/L	monthly	12	<5	12	1,600	9	yes
carbonaceous biochemical oxygen demand	mg/L	every 6 days	61	<2	2	15	<2	yes
chlorine (total residual)	mg/L	every 6 days	61	<0.04	<0.04	0.1	<0.04	yes
cobalt	ug/L	monthly	12	0.2	0.8	2.4	0.6	yes
copper	ug/L	monthly	12	4.3	10.5	160	7	yes
diazinon	ug/L	monthly	12	<0.1	<0.1	2.4	<0.1	yes
iron	ug/L	monthly	12	78	828	6,500	826	yes
nitrogen (ammonia)	mg/L	every 6 days	61	0.01	5.71	5	2.8	yes
nitrogen (total)	mg/L	every 6 days	61	5.42	12.8	15	9.9	yes
phosphorus (total)	mg/L	every 6 days	61	0.05	0.47	3	0.26	yes
total suspended solids	mg/L	every 6 days	61	<2	12	15	<2	yes
zinc	ug/L	monthly	12	11	60	230	22	yes

Winmalee Wastewater Treatment Plant

2019-20 Pollution monitoring yearly limit summaries



EPL 1963

Summary period: 01-07-2019 to 30-06-2020

Date published: 10-08-2020

Licensee: Sydney Water Corporation

PO Box 399

PARRAMATTA NSW 2124

Average yearly summary								
EPA Point 4 Site code WM0004		Point description: Downstream of the chamber prior to discharge						
pollutant	unit of measure	sampling frequency	number of samples	minimum result	maximum result	Average Limit	Average value	within limits
aluminium	ug/L	monthly	12	<5	12	190	6	yes
cobalt	ug/L	monthly	12	0.2	0.8	1.6	0.5	yes
copper	ug/L	monthly	12	4.3	10.5	20	6	yes
diazinon	ug/L	monthly	12	<0.1	<0.1	0.3	<0.1	yes
iron	ug/L	monthly	12	78	828	830	515	yes
zinc	ug/L	monthly	12	11	60	40	20	yes